


## NOTES:

1. CSBC DEPTH SHALL BE A MINIMUM 6" OR MATCH EXISTING WHICHEVER IS GREATER. CSBC SHALL BE INSTALLED IN MULTIPLE LIFTS OF EQUAL THICKNESS WHEN EXCEEDING 6" THICKNESS.
2. ROADWAY HMA DEPTH SHALL BE A MINIMUM OF 2" THICK. UNLESS APPROVED BY THE ENGINEER, ANY DEPTH GREATER THEN 2" SHALL MATCH EXISTING.
3. FINAL PAVEMENT JOINTS SHALL BE NEATLY AND UNIFORMLY SEALED PER WSDOT STANDARD SPECIFICATIONS 5-04.3(4)A.
4. REFER TO EDMONDS COMMUNITY DEVELOPMENT CODE TABLE OF STREET STANDARDS FOR EASEMENT AND PAVEMENT WIDTHS.
5. FIRE DEPARTMENT MAY REQUIRE ACCESS TO BE WIDER IF IT IS DETERMINED FIRE FIGHTING OR RESCUE OPERATIONS ARE HAMPERED.
6. 6" CONCRETE EXTRUDED CURB OR 18" ASPHALT THICKENED EDGE REQUIRED (REFER TO CITY STANDARD CURB DETAILS).



**CITY OF EDMONDS**  
PUBLIC WORKS  
DEPARTMENT

**PRIVATE STREET  
(1-4 LOTS)**

APPROVED BY: R. ENGLISH

REVISION DATE  
FEBRUARY 2020

STANDARD  
DETAIL  
**TR-510**